

July 6, 2026

AMENDMENT NO. 1  
TO  
RFB-2025-017R


DR-4625NY CITY OF ROME DISASTER RECOVERY – PHASE 2

BID OPENING  
July 9, 2026 @ 11:0 AM AT ROME CITY HALL

---

**NOTE:** This amendment shall be attached to and become a part of the Proposal for **RFB-2025-017R** as outlined below:

- Question:** Are all the concrete bollards near the pavilion to be removed?
  - Answer:** Per callout on GNP-03, Existing bollard (typ) to be removed. Cost included under Item 203.02
- Question:** On Drawing GNP-03, is the area called out for parking lot repaving to be milled? Detail 3 on Drawing TYP-02 only shows top course. Is this to be placed on top of the existing pavement?
  - Answer:** See Dwg GNP-03 for legend of location for asphalt milling and asphalt overlay. Milling is only anticipated in hatched areas as shown.
- Question:** We are having trouble finding the detail for the 2X2 City of Rome Standard Catch Basins. Can a detail be provided?
  - Answer:** Please see screen shot of the City Detail below



4. **Question:** Please confirm that the concrete for the sidewalks and pier are legacy class D and that PEM is not required.

- **Answer:** All concrete will be legacy Class D as noted on MSD-03. There is no NYSDOT funding so NO PEM concrete is required.

5. **Question:** For item 655.1201RC CITY OF ROME STANDARD CAST DRAINAGE FRAME AND GRATE, please confirm that The City of Rome will furnish the frames and grates and that this item is install only. (Per note 2 of the detail on Drawing MSD-04).

- **Answer:** Per note 2 on MSD-04, the City of Rome Standard Cast Drainage Frame and Grate shall be supplied by the City of Rome.

All Bidders **MUST** complete acknowledging receipt of this amendment and attached to their respective bids. If the Bidder fails to complete the 'Amendment Acknowledgement' below, his bid could be declared informal thereby delaying award of the contract.

**PLEASE BE GOVERNED ACCORDINGLY WHEN SUBMITTING BIDS.**

Company Name: \_\_\_\_\_

Address: \_\_\_\_\_

Date: \_\_\_\_\_

Contact Name: \_\_\_\_\_

Contact Signature: \_\_\_\_\_



**END ADDENDUM NO. 1**